


COUNTY COMMISSIONERS

Carolina Mejia
District OneGary Edwards
District TwoTye Menser
District Three

THURSTON COUNTY

WASHINGTON

SINCE 1852


PUBLIC HEALTH AND
SOCIAL SERVICES DEPARTMENT

MEMORANDUM

August 17, 2023

David Bayne, MPH
DirectorDimyana Abdelmalek, MD, MPH
Health Officer

TO: Heather Tschaekofske, Thurston County Community Planning & Economic Development


FROM: Kyle Overton, Thurston County Environmental Health Division 

SUBJECT: Project 2023101504, Folder Sequence 23-103942 XC
Parcel 45800201500, Austin-Daniells JARPA Shoreline Substantial Development Application

The above-referenced project has been routed to this department for review and comment. This project is proposing to install a slope retention system. The property is served by the Edgewater Beach Group A water system ID#22416 and an onsite sewage system (OSS). **Environmental Health's review is complete and has no objection to this project with the following comment:**

1. The staging area for all construction vehicles, equipment, and materials shall be maintained off the on-site sewage system components and drainfield area to ensure they are protected from damage during construction.

If you or the applicants have any questions regarding Environmental Health's review, I can be reached at (360) 867-2654 or kyle.overton@co.thurston.wa.us.



THURSTON COUNTY
WASHINGTON
SINCE 1852

COUNTY COMMISSIONERS

Carolina Mejia
District One

Gary Edwards
District Two

Tye Menser
District Three

**PUBLIC HEALTH AND
SOCIAL SERVICES DEPARTMENT**


MEMORANDUM

October 31, 2023

David Bayne, MPH
Director

Dimyana Abdelmalek, MD, MPH
Health Officer

TO: Heather Tschaekofske, Thurston County Community Planning & Economic Development

FROM: Kyle Overton, Thurston County Environmental Health Division 

SUBJECT: Project 2023101504, Folder Sequence 23-103942 XC, 23-112946 XK
Parcel 45800201500, Austin-Daniells JARPA Shoreline Substantial Development and Conditional Use Permit Application

The above-referenced project has been routed to this department for review and comment. This project is proposing to install a slope retention system. The property is served by the Edgewater Beach Group A water system ID#22416 and an onsite sewage system (OSS). **Environmental Health's review is complete and has no objection to this project with the following comment:**

1. The staging area for all construction vehicles, equipment, and materials shall be maintained off the on-site sewage system components and drainfield area to ensure they are protected from damage during construction.

If you or the applicants have any questions regarding Environmental Health's review, I can be reached at (360) 867-2654 or kyle.overton@co.thurston.wa.us.

Jim Hunter & Associates

LOCATION: 2201 "A" 93RD Avenue SW • Olympia, WA 98512-9195

MAILING: P.O. Box 162 • Olympia, WA 98507

(360) 753-1226 • FAX: (360) 705-1360 • EMAIL: jhandassociates@hotmail.com

SEPTIC SYSTEM DESIGNERS

To: Thurston County Environmental Health
From: Adam Hunter – Licensed Onsite Sewage System Designer
Subject Parcel: 2725 Schirm Loop NW
45800201500
Regarding: 1983 Drainfield Expansion Record Drawing
CC: Thomas Daniells - Owner

Mr. Overton,

The owner of 2725 Schrim Loop NW (Thomas Daniells) has agreed to abandon the added septic lines shown on the 1983 Record Drawing (approximately 60ft of drainfield) to restore his septic system to the originally permitted (0638 – 1975) 20ft deep trench system. This work is to be conducted in parallel with the shoreline project and the drainfield will be marked at the time of abandonment to prevent damage from equipment during the shoreline stabilization.

The 20ft deep trench appears to be functioning at this time and the system will not be compromised by this repair activity. In addition the work will be done by a Thurston County Licensed Septic Installer. Once the work is completed a letter must be submitted to Thurston county by either the installer or designer.

If you have any questions please call: 360-753-1226

Best regards,

Adam Hunter